

Consumer Confidence Report

Annual Drinking Water Quality Report

LOVINGTON
IL1390250

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by LOVINGTON is Ground Water

For more information regarding this report contact:

Name

Chris Ellis

Phone

217-873-4480

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo a habla con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. EPA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested. Contact Miss Gills at 217-973-4884 for information on lead in drinking water, testing methods, and steps you can take to minimize exposure. Information is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 10 (00976)	GW	<i>ACTIVE</i>	
WELL 5 (45009)	OLD PENNRR WELL	<i>ACTIVE</i>	
WELL 7 (45011)	GW	<i>Active</i>	NORTH OF TOWN
WELL 9 (00355)	GW	<i>Active</i>	

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 317-833-4480 to view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: LOVINGTON To determine Lovington's susceptibility to groundwater contamination, a Well Site Survey, published in 1994 by the Illinois EPA, and Source Water Protection Plan were reviewed. Based on the information contained in these documents, fifteen potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Lovington community water supply wells. These include a mining, a pesticide/fertilizer application or warehouse, two machine shops/sheds, an above or below ground fuel storage, a grain elevator, a store/sales, four below ground fuel storages, a fire station, an office, an equipment/vehicle washing, and a restaurant/food services. Inactive Wells #2 and #3 are also considered potential routes of contamination based upon this information, the Illinois EPA has determined that Lovington Wells #5, #7, #9, and #10 are not susceptible to IOC or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells.

2025 Regulated Contaminants Detected

Lead and Copper

Definitions: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
 Action Level: The level of a contaminant in drinking water below which there is no known or expected risk to health. AIGs allow for a margin of safety.

Copper Range: 0 to 1.680 mg/L
 Lead Range: 0 to 0.057 mg/L

To obtain a copy of the system's lead tap sampling data: CALL 217-873-4480 - Chris Gillis

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory: CAD 217-873-4480 - Chris Gillis

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	1.16	2	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

Water Quality Test Results

mrem: millirems per year (a measure of radiation absorbed by the body)
ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Chlorine	Halooacetic Acids (HAA5)	Total Trihalomethanes (TTHM)	Inorganic Contaminants	Arsonic - While Your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPAs standard balances the current understanding of arsenics possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.	Barium	Fluoride	Sodium		
Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date		
Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected		
Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected		
MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG		
MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL		
Units	Units	Units	Units	Units	Units	Units	Units	Units		
Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation		
Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination		
	1.3	24	8	8	7.48 - 8.46	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
	1 - 2.5	24.3 - 24.3	7.8 - 7.8	No goal for the total				ppm	N	Water additive used to control microbes.
				MRDLG = 4				ppm	N	By-product of drinking water disinfection.
				MRDL = 4				ppb	N	By-product of drinking water disinfection.
				80				ppb	N	By-product of drinking water disinfection.
								ppb	N	Likely Source of Contamination
								ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
								ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
								ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCIG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	05/05/2020	2.29	2.29 - 2.29	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	05/05/2020	0.08	0.08 - 0.08	0	15	pCi/L	N	Erosion of natural deposits.